

# CERTIFICATE OF COMPLIANCE



## Da-Lite Screen Company

### High Contrast Da-Tex

Restrictions:

UL 2818 - 2013 Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Interior finishes and furnishings are determined compliant in accordance with an Office environment with an air change of  $0.68 \text{ hr}^{-1}$  and a loading of  $2.30 \text{ m}^2$ .

Products tested in accordance with UL 2821 test method to show compliance to emission limits in UL 2818, Section 7.1.

5114-410

Certificate Number

06/25/2008 - 01/30/2019

Certificate Period

Certified

Status



**Environment**

## GREENGUARD Certification Criteria for Furniture and Mattresses

Criteria	CAS Number	Maximum Allowable Predicted Concentration	Units
TVOC <sup>(A)</sup>	-	0.50	mg/m <sup>3</sup>
Formaldehyde	50-00-0	61.3 (50 ppb)	µg/m <sup>3</sup>
Total Aldehydes <sup>(B)</sup>	-	0.10	ppm
4-Phenylcyclohexene	4994-16-5	6.5	µg/m <sup>3</sup>
Individual VOCs <sup>(C)</sup>	-	1/10th TLV	-

- (A) Defined to be the total response of measured VOCs falling within the C<sub>6</sub> – C<sub>16</sub> range, with responses calibrated to a toluene surrogate.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Allowable levels for chemicals not listed are derived from 1/10th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



**Environment**